

Planning and Development Services Department

Project Address: _____ **Project Name:** _____

Permit # _____ **Special Inspection Agency or Agent:** _____

This is to certify that I or qualified individual(s) working under my direction inspected and/or tested the following items in accordance with the City of Overland Park Design and Construction Standards, approved plans and specifications. I have found that the work is in substantial compliance with the City of Overland Park Design and Construction Standards, approved plans and specifications.

Check appropriate items for Bioretention Cells:

- | | |
|---|--|
| <input type="checkbox"/> SOIL AMENDMENTS MEET REQUIREMENTS;
DELIVERY TICKET REQUIRED | <input type="checkbox"/> FINAL GRADES, LOCATIONS, VOLUME
CONFORM WITH CONSTRUCTION PLANS |
| <input type="checkbox"/> PRETREATMENT DEVICE INSTALLED AT
LOCATION/ELEVATION SHOWN ON PLANS | <input type="checkbox"/> GRAVEL WASHED ON SITE PRIOR TO
PLACEMENT |
| <input type="checkbox"/> UNDERDRAIN, CLEANOUTS, GRAVEL BED,
AND FILTER FABRIC INSTALLED PER PLANS | <input type="checkbox"/> OVERFLOW INSTALLED AT LOCATION/
ELEVATIONS SHOWN ON PLANS |
| <input type="checkbox"/> STAFF GAGE OR VERTICAL MARKER
PROVIDED FOR SEDIMENT FOREBAY (IF REQ'D) | <input type="checkbox"/> MULCH NETTING INSTALLED PER
MANUFACTURER'S SPECIFICATIONS |
| <input type="checkbox"/> PLANT MATERIALS MEET SIZE, DENSITY, TYPE
AND LOCATION AS SHOWN ON PLANS | <input type="checkbox"/> TYPE AND THICKNESS OF MULCH
INSTALLED PER PLANS |
| <input type="checkbox"/> PERCOLATION RATE TESTED PRIOR TO PLANT
INSTALLATION; PERCOLATION RATE SUFFICIENT
TO INFILTRATE ENTIRE FACILITY WITHIN 48 HOURS | <input type="checkbox"/> MINIMUM 6" FREEBOARD BETWEEN
OVERFLOW AND LOWEST ADJACENT
PAVEMENT ELEVATIONS |
| <input type="checkbox"/> ORIFICE INSTALLED AT OUTLET STRUCTURE | <input type="checkbox"/> OTHER _____ |

Professional Seal _____

Signature _____ **Date** _____

Submit to: Engineering Services Division
Planning and Development Services Department
City of Overland Park,
8500 Santa Fe Drive,
Overland Park, KS 66212
eod@opkansas.org
Phone: 913-895-6223 Fax: 913-895-5016