

**CITY OF OVERLAND PARK
INTRACITY COMMUNICATION**

PLANNING AND DEVELOPMENT SERVICES

October 4, 2016

Rhonda Clark - SPS

**MILLS FARM, FOURTEENTH PLAT
ESR2014-00079**

NOTE: Building Permits will not be issued until the applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.

LOTS NOT AVAILABLE FOR PERMIT AT THIS TIME

Lot 318 Sediment Basin

Lot 319 Sediment Basin

SWALE GRADING

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm energy grade line as measured perpendicular to the swale.

<u>LOT</u>	<u>SWALE</u>	<u>EGL DEPTH (FEET)</u>
318	A-A	0.94
319	A-A	0.94

MLO SET BY ENGINEER

The following lots are adjacent to large open stormwater conveyances which require freeboard for all building openings and tops of foundation walls. An engineered plot plan is required for these lots which show the minimum low opening established on the subdivision as-built grading plan and actual proposed building openings and top of foundation wall elevations.

<u>LOT</u>	<u>MLO (All Building Openings)</u>
309	998.0

310
311
312

998.0
998.0
998.0

FOUNDATION INVESTIGATION

The following lots are constructed over areas that require special foundation designs to minimize potential for geotechnical related problems. The foundation investigation must be submitted and approved prior to a footing inspection. An Engineered plot plan is NOT required for this condition.

LOT

CONDITION

318
319

If you have any questions, please contact me.



David D. Miller, P.E.
Supervisory Civil Engineer

c: Phelps Engineering, Inc
Tony Meyers, Manager Engineering Services
Mills Farm, Fourteenth Plat
Matt Adam
City website