

INTRACITY COMMUNICATION

August 28, 2014

Rhonda Clark – SPS

**STONEGATE RESERVE 2nd PLAT – FULL RELEASE
ESR2013-00024**

NOTE 1: *Building Permits will not be issued until the applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.*

SWALE GRADING

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm Energy Grade Line (EGL) as measured perpendicular to the swale.

<u>LOT</u>	<u>SWALE</u>	<u>EGL DEPTH (FEET)</u>
59	1-1	0.96
60	1-1	0.96

MLO SET BY ENGINEER

The following lots are adjacent to large open stormwater conveyances which require freeboard for all building openings and tops of foundation walls. An engineered plot plan is required for these lots which show the minimum low opening established on the subdivision as-built grading plan and actual proposed building openings and top of foundation wall elevations.

<u>LOT</u>	<u>MLO (All Building Openings)</u>
51	994.2
52	994.2
53	994.2
58	994.2
59	994.2
60	994.3
61	994.5
62	995.1

Stonegate Reserve 2nd Plat
August 28, 2014
Page 2

(CONTINUED)

LOT

63
64

MLO (All Building Openings)

995.2
996.1

If you have any questions, please contact me.



Alysen M. Abel, P.E.
Civil Engineer, Senior

c: Mark Breuer, P.E. – Schlagel & Associates
Dan White – Construction Inspector, Senior
Corey Walker – Mariner Real Estate
Stonegate Reserve 2nd Plat – Flood File